



GOVERNMENT OF KARNATAKA
KARNATAKA STATE FIRE AND EMERGENCY SERVICES
OFFICE OF THE FIRE STATION OFFICER, FIRE STATION HUVINA HADAGALI
PIN-583219 TELEPHONE-08399-240201



SLNO: 23/FSO/HPT/HH/2020

DATE : 25-01-2020


FIRE SAFETY CERTIFICATE

Certified that the JSS PUBLIC SCHOOL , Sy No 684, HUVINA HADAGALI 583219. Comprised of the one Ground floor of building occupied by the Executive Secretary , Sri Shivaratri Rajendra circle JSS Mahavidyapeeta Mysuru-570004, Have complied with the fire prevention and fire safety requirements in accordance with rule of state/UT fire service rules, fire prevention equipment of 20 No's of portable fire extinguishers given below. Have been adopted, Hence these fire extinguishers are fit for one year from date of issuing this certificate

Sl no	Description	Capacity	Number of extinguishers	Condition
01	Dry chemical Powder (DCP)	05 kg	02	GOOD
02	Water type (co2 cartridge)	09 litre	10	GOOD
03	CO2 type	02 kg	04	GOOD
04	CO2 type (trolley)	6.5 kg	01	GOOD
05	ABC type	6 kg	03	GOOD

TO,
THE PRINCIPAL
JSS PUBLIC SCHOOL
Sy No 684
HUVINA HADAGALI-583219
BALLARI DIST

PRINCIPAL
JSS PUBLIC SCHOOL
Huvina Hadagali-583 219
Ballari District


FIRE STATION OFFICER
FIRE STATION
Huvinahadagali-583219
BALLARI. Dt.


PRINCIPAL
JSS PUBLIC SCHOOL
Huvina Hadagali-583219
Ballari Dist