

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. TEE/ RWSKS)subdiv) Hd1/2026-27/ 317

Dated: 25-08-2026

It is certified that an inspection team headed by Sri. Pradeep Kumar

Assistant Executive Engineer.

(Name of Officers with designation)

from Rural Drinking water & Sanitation Department sub div Huvinahadagali

PHED

inspected the JSS public school Hologundi, Huvinahadagali Taluk

(Name & Address of the school) on 21.08.2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. TEU426AUG3360

dated 24.08.2026 of PDWSO Testing Lab - Huvinahadagali

(PHED Lab)

certified that the JSS Public school Hologundi
Huvinahadagali (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 24-09-2026 to 23-09-2027

Signature with Seal:

Name

Sri. Pradeep Kumar

Designation

ಹಿರಿಯರ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರ

Name & Address of

ರೂರಲ್ ಡ್ರಿಂಗ್‌ವಾಟರ್ & ಸನಿಟೇಷನ್ ಡಿಪಾರ್ಟ್‌ಮೆಂಟ್

ಹುಲ-ವಿಭಾಗ, ಹುಲಿನಹದಗಲಿ

To The Principal JSS public school
Hologundi, Huvinahadagali (Taluk)

(Name & Address of the Institution) Wijayanagara dist.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Vijayanagara District Water Quality Testing Laboratory, Huvinahadagali
Near Rangabharathi Park, Beside PRED Office, Harappanahalli Road, Huvinahadagali-583219
Gmail: rdwsd.wqmsh.hadagalilab51@gmail.com

TEST REPORT

To, Costumer Name : The Principal JSS Public School Name of District : Vijayanagara Name of Taluka : Huvinahadagali Location of Source : At JSS School RO Water	Report Date	: 24.08.2026
	Report Number	: RDWS/AUG/330/2026-27
	Reference	: Sample Received By Hand
	Sample Receipt Date	: NA
	Sample Code	: HUH26AUG330
	Date of Sample Collection	: 21.08.2026
	Analysis Start Date	: 21.08.2026
	Analysis Completion Date	: 24.08.2026
	Temperature	: at 25°C
	Sample Collection Protocol	: RDWS/D/WQMSP/SOP/23

Sample Particulars: RO Drinking Water

Sample Quantity : 1000ml

Sl. No.	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colorless Liquid					
1	pH Value @ Temp 25°C	7.52	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Odour	Agreeable	Agreeable	Agreeable	IS 3025(Part-5&6)-2018
3	Taste	Agreeable	Agreeable	Agreeable	IS 3025(Part-8):2017
4	Colour, Hazen Unit	5	5	15	IS 3025(Part-4): 2021
5	Total Dissolved Solids @180°C, mg/l	52	500	2000	IS 3025 (Part-16) : 2023
6	Specific Conductance @25°C, µS/cm	86	—	—	IS 3025 (Part-14) : 2013
7	Total Hardness as CaCO ₃ , mg/l	20.0	200	600	IS 3025 (Part-21) : 2009
8	Calcium as Ca, mg/l	4.80	75	200	IS 3025 (Part-40) : 2024
9	Magnesium as Mg, mg/l	1.94	30	100	IS 3025 (Part-46) : 2023
10	Chloride as Cl, mg/l	7.94	250	1000	IS 3025 (Part-32) : 1988,RA:2025
11	Alkalinity as CaCO ₃ , mg/l	16.0	200	600	IS 3025 (Part-23) : 2023
12	Turbidity, NTU	0.1	1	5	IS 3025 (Part-10) : 2023
13	Sulphate as SO ₄ mg/l	7.21	200	400	IS 3025 (Part-24) : 2022
14	Nitrate as NO ₃ , mg/l	3.92	45	No relaxation	APHA 24th Edition: 4500,NO3–B
15	Iron as Fe, mg/l	0.071	1	No relaxation	IS 3025 (Part-53) : 2024
16	Fluoride as F, mg/l	0.00	1	1.5	APHA 24th Edition: 4500F-D

Remark : The given sample confirms to the acceptable & Permissible limits of IS:10500:2012 RA 2018 Drinking water specifications for above tested physical & chemical parameters.

Analysed By

(Signature)
Analyst
LAB CHEMIST
(Bingh Raju)

Authorised Signatory

(Signature)
Assistant Executive Engineer
(Pradeepkumar)
Rural Drinking Water & Sanitation Sub-Division
HUVINAHADAGALI
RDWS/D/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWS/D/WQMSP/DR-01

End of Report